



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081217

High Desert ESD 2804 SW 6th Street Redmond, OR 97756 55246	Project: General Project #: Prineville Education Center Client Contact: Bob Martin	Date Reported: 08/22/16 Date Received: 08/12/16 07:29 Sampled By:
---	--	---

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6081217-01	Sample Location: Men's Bathroom Sink									
	Lead	1030	0.002	mg/L	0.002	0.015	08/11/16 06:03	08/15/16	DJP	
	Copper		0.162	mg/L	0.010	1.3	08/11/16 06:03	08/15/16	DJP	
6081217-02	Sample Location: Womens Bathroom Sink									
	Lead	1030	0.002	mg/L	0.002	0.015	08/11/16 06:07	08/15/16	DJP	
	Copper		0.144	mg/L	0.010	1.3	08/11/16 06:07	08/15/16	DJP	
6081217-03	Sample Location: Staffroom Sink									
	Lead	1030	0.004	mg/L	0.002	0.015	08/11/16 06:08	08/15/16	DJP	
	Copper		0.203	mg/L	0.010	1.3	08/11/16 06:08	08/15/16	DJP	
6081217-04	Sample Location: Hallway Sink									
	Lead	1030	0.003	mg/L	0.002	0.015	08/11/16 06:19	08/15/16	DJP	
	Copper		0.159	mg/L	0.010	1.3	08/11/16 06:19	08/15/16	DJP	
6081217-05	Sample Location: Girls Bathroom Sink									
	Lead	1030	0.004	mg/L	0.002	0.015	08/11/16 06:11	08/15/16	DJP	
	Copper		0.171	mg/L	0.010	1.3	08/11/16 06:11	08/15/16	DJP	
6081217-06	Sample Location: Boys Bathroom Sink									
	Lead	1030	0.002	mg/L	0.002	0.015	08/11/16 06:02	08/15/16	DJP	
	Copper		0.177	mg/L	0.010	1.3	08/11/16 06:02	08/15/16	DJP	
6081217-07	Sample Location: Classroom 118 Sink									
	Lead	1030	0.002	mg/L	0.002	0.015	08/11/16 06:18	08/15/16	DJP	
	Copper		0.209	mg/L	0.010	1.3	08/11/16 06:18	08/15/16	DJP	
6081217-08	Sample Location: Classroom 119 Sink									
	Lead	1030	0.002	mg/L	0.002	0.015	08/11/16 06:15	08/15/16	DJP	
	Copper		0.186	mg/L	0.010	1.3	08/11/16 06:15	08/15/16	DJP	
6081217-09	Sample Location: Hallway Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081217

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.015	08/11/16 06:05	08/15/16	DJP	
Copper			0.310	mg/L	0.010	1.3	08/11/16 06:05	08/15/16	DJP	
6081217-10	Sample Location: South Ext. Hose Bib									
Lead		1030	0.007	mg/L	0.002	0.015	08/11/16 06:20	08/15/16	DJP	
Copper			0.165	mg/L	0.010	1.3	08/11/16 06:20	08/15/16	DJP	

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081217

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.