

Water Testing Results - High Desert ESD HDREC

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Test Date	Test Result
North upstairs mens sink	8/24/2016	2
South upstairs mens sink	8/24/2016	4
North upstairs womens sink	8/24/2016	ND
South upstairs womens sink	8/24/2016	ND
Upstairs kitchen sink	8/24/2016	ND
Upstairs refrigerator	8/24/2016	ND
North downstairs mens sink	8/24/2016	2
South downstairs mens sink	8/24/2016	2
North downstairs womens sink	8/24/2016	ND
South downstairs womens sink	8/24/2016	ND
Downstairs unisex sink	8/24/2016	ND
Downstairs kitchen sink	8/24/2016	ND
Downstairs refrigerator	8/24/2016	ND
West hose bibb	8/24/2016	24

ND = Non Detect - Lead level is below the set detection limit of 2 ppb