

Water Testing Results - High Desert ESD Manzanita

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Test Date	Test Result
Boys bathroom north sink	8/11/2016	ND
Mens bathroom north sink	8/11/2016	3
Mop sink faucet	8/11/2016	9
Classroom C upper sink	8/11/2016	ND
East hose bibb	8/11/2016	ND
South drinking fountain	8/11/2016	ND
North drinking fountain	8/11/2016	ND
Womens bathroom south sink	8/11/2016	ND
West hose bibb	8/11/2016	60
Classroom A lower sink	8/11/2016	2
Girls bathroom south sink	8/11/2016	ND
Classroom C lower sink	8/11/2016	2
Girls bathroom north sink	8/11/2016	ND
Classroom A upper sink	8/11/2016	2
Womens bathroom north sink	8/11/2016	ND
Mens bathroom south sink	8/11/2016	ND
Laundry tub faucet	8/11/2016	ND
Classroom B lower sink	8/11/2016	4
Boys bathroom south sink	8/11/2016	ND
Classroom B Upper sink	8/11/2016	2
Kitchen break room sink	8/11/2016	ND
West hose bibb	8/30/2016	8

ND = Non Detect - Lead level is below the set detection limit of 2 ppb