

**Water Testing Results - High Desert ESD Prineville
Education Center
Action Level is 15 parts per billion (ppb)**

Fixture Location/Description	Test Date	Test Result
Mens bathroom sink	8/11/2016	2
Womens bathroom sink	8/11/2016	2
Staffroom sink	8/11/2016	4
Hallway sink	8/11/2016	3
Girls bathroom sink	8/11/2016	4
Boys bathroom sink	8/11/2016	2
Classroom 118 sink	8/11/2016	2
Classroom 119 sink	8/11/2016	2
Hallway drinking fountain	8/11/2016	ND
South hose bibb	8/11/2016	7

ND = Non Detect - Lead level is below the set detection limit of 2 ppb