



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081824

High Desert ESD 2804 SW 6th Street Redmond, OR 97756 55288	Project: General Project #: Skyliner Lodge Client Contact: Bob Martin	Date Reported: 08/28/16 Date Received: 08/18/16 11:30 Sampled By: Bob Martin
---	---	--

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6081824-01	Sample Location: North Bathroom Sink									
	Lead	1030	0.002	mg/L	0.002	0.015	08/17/16 02:30	08/23/16	DJP	
	Copper		0.046	mg/L	0.010	1.3	08/17/16 02:30	08/23/16	DJP	
6081824-02	Sample Location: South Bathroom Sink									
	Lead	1030	ND	mg/L	0.002	0.015	08/17/16 02:35	08/23/16	DJP	
	Copper		0.043	mg/L	0.010	1.3	08/17/16 02:35	08/23/16	DJP	
6081824-03	Sample Location: Large Kitchen Sink									
	Lead	1030	ND	mg/L	0.002	0.015	08/17/16 02:40	08/23/16	DJP	
	Copper		0.062	mg/L	0.010	1.3	08/17/16 02:40	08/23/16	DJP	
6081824-04	Sample Location: Small Kitchen Sink									
	Lead	1030	ND	mg/L	0.002	0.015	08/17/16 02:45	08/23/16	DJP	
	Copper		0.072	mg/L	0.010	1.3	08/17/16 02:45	08/23/16	DJP	
6081824-05	Sample Location: West FP Hydrant									
	Lead	1030	0.104	mg/L	0.002	0.015	08/17/16 07:23	08/24/16	DJP	CON-1
	Copper		3.965	mg/L	0.010	1.3	08/17/16 07:23	08/24/16	DJP	CON-1
6081824-06	Sample Location: South FP Hydrant									
	Lead	1030	0.002	mg/L	0.002	0.015	08/17/16 07:20	08/23/16	DJP	
	Copper		0.014	mg/L	0.010	1.3	08/17/16 07:20	08/23/16	DJP	
6081824-07	Sample Location: Boys FP Hydrant									
	Lead	1030	ND	mg/L	0.002	0.015	08/17/16 07:40	08/23/16	DJP	
	Copper		ND	mg/L	0.010	1.3	08/17/16 07:40	08/23/16	DJP	
6081824-08	Sample Location: Girls FP Hydrant									
	Lead	1030	ND	mg/L	0.002	0.015	08/17/16 07:30	08/23/16	DJP	
	Copper		ND	mg/L	0.010	1.3	08/17/16 07:30	08/23/16	DJP	
6081824-09	Sample Location: Parking FP Hydrant									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081824

Method: EPA 200.8

Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.015	08/17/16 07:35	08/23/16	DJP	
Copper			0.011	mg/L	0.010	1.3	08/17/16 07:35	08/23/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081824

Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager