

# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: http://ChemLab.cc  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6081218

High Desert BSD 2804 SW 6th Street Redmond, OR 97756 55246	Project: General Project #: Manzanita Building Client Contact: Bob Martin	Date Reported: 08/22/16 Date Received: 08/12/16 07:29 Sampled By: Bob Martin
---	---	--

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6081218-01	Sample Location: Boys Bathroom North Sink									
	Lead	1030	ND	mg/L	0.002	0.015	08/11/16 07:32	08/15/16	DJP	
	Copper		0.236	mg/L	0.010	1.3	08/11/16 07:32	08/15/16	DJP	
6081218-02	Sample Location: Mens Bathroom North Sink									
	Lead	1030	0.003	mg/L	0.002	0.015	08/11/16 07:52	08/15/16	DJP	
	Copper		0.197	mg/L	0.010	1.3	08/11/16 07:52	08/15/16	DJP	
6081218-03	Sample Location: Mop Sink Faucet									
	Lead	1030	0.009	mg/L	0.002	0.015	08/11/16 07:44	08/15/16	DJP	
	Copper		0.085	mg/L	0.010	1.3	08/11/16 07:44	08/15/16	DJP	
081218-04	Sample Location: Classroom C Uppersink									
	Lead	1030	ND	mg/L	0.002	0.015	08/11/16 08:04	08/15/16	DJP	
	Copper		0.143	mg/L	0.010	1.3	08/11/16 08:04	08/15/16	DJP	
6081218-05	Sample Location: East Hose Bib									
	Lead	1030	ND	mg/L	0.002	0.015	08/11/16 08:10	08/15/16	DJP	
	Copper		0.123	mg/L	0.010	1.3	08/11/16 08:10	08/15/16	DJP	
6081218-06	Sample Location: South Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.015	08/11/16 07:54	08/15/16	DJP	
	Copper		0.105	mg/L	0.010	1.3	08/11/16 07:54	08/15/16	DJP	
6081218-07	Sample Location: North Drinking Fountain									
	Lead	1030	ND	mg/L	0.002	0.015	08/11/16 07:56	08/15/16	DJP	
	Copper		0.109	mg/L	0.010	1.3	08/11/16 07:56	08/15/16	DJP	
6081218-08	Sample Location: Womens Bathroom South Sink									
	Lead	1030	ND	mg/L	0.002	0.015	08/11/16 07:18	08/15/16	DJP	
	Copper		0.151	mg/L	0.010	1.3	08/11/16 07:18	08/15/16	DJP	
6081218-09	Sample Location: West Hose Bib									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAPID# OR100031

## ANALYSIS REPORT

URC # 6081218

Matrix: Drinking Water

Method: EPA 200.8


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.060	mg/L	0.002	0.015	08/11/16 08:12	08/17/16	DJP	CON-1
Copper			0.232	mg/L	0.010	1.3	08/11/16 08:12	08/17/16	DJP	
6081218-10	Sample Location: Classroom A Lower Sink									
Lead		1030	0.002	mg/L	0.002	0.015	08/11/16 07:58	08/15/16	DJP	
Copper			0.113	mg/L	0.010	1.3	08/11/16 07:58	08/15/16	DJP	
6081218-11	Sample Location: Girls Bathroom South Sink									
Lead		1030	ND	mg/L	0.002	0.015	08/11/16 07:38	08/15/16	DJP	
Copper			0.216	mg/L	0.010	1.3	08/11/16 07:38	08/15/16	DJP	
6081218-12	Sample Location: Classroom C Lower Sink									
Lead		1030	0.002	mg/L	0.002	0.015	08/11/16 08:06	08/15/16	DJP	
Copper			0.209	mg/L	0.010	1.3	08/11/16 08:06	08/15/16	DJP	
6081218-13	Sample Location: Girls Bathroom North Sink									
Lead		1030	ND	mg/L	0.002	0.015	08/11/16 07:36	08/15/16	DJP	
Copper			0.166	mg/L	0.010	1.3	08/11/16 07:36	08/15/16	DJP	
6081218-14	Sample Location: Classroom A Upper Sink									
Lead		1030	0.002	mg/L	0.002	0.015	08/11/16 08:08	08/15/16	DJP	
Copper			0.207	mg/L	0.010	1.3	08/11/16 08:08	08/15/16	DJP	
6081218-15	Sample Location: Womens Bathroom North Sink									
Lead		1030	ND	mg/L	0.002	0.015	08/11/16 07:46	08/15/16	DJP	
Copper			0.160	mg/L	0.010	1.3	08/11/16 07:46	08/15/16	DJP	
6081218-16	Sample Location: Mens Bathroom South Sink									
Lead		1030	ND	mg/L	0.002	0.015	08/11/16 07:50	08/15/16	DJP	
Copper			0.157	mg/L	0.010	1.3	08/11/16 07:50	08/15/16	DJP	
6081218-17	Sample Location: Laundry Tub Faucet									
Lead		1030	ND	mg/L	0.002	0.015	08/11/16 07:12	08/15/16	DJP	
Copper			0.026	mg/L	0.010	1.3	08/11/16 07:12	08/15/16	DJP	
6081218-18	Sample Location: Classroom B Lower Sink									
Lead		1030	0.004	mg/L	0.002	0.015	08/11/16 08:02	08/15/16	DJP	
Copper			0.287	mg/L	0.010	1.3	08/11/16 08:02	08/15/16	DJP	
6081218-19	Sample Location: Boys Bathroom South Sink									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



**UMPQUA Research Company**

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: http://ChemLab.cc  
ORELAP ID# OR100031

**ANALYSIS REPORT**  
**URC # 6081218**

Method: EPA 200.8


Matrix: Drinking Water

	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	ND	mg/L	0.002	0.015	08/11/16 07:34	08/15/16	DJP	
Copper			0.179	mg/L	0.010	1.3	08/11/16 07:34	08/15/16	DJP	
6081218-20	Sample Location: Classroom B Upper Sink									
Lead		1030	0.002	mg/L	0.002	0.015	08/11/16 08:00	08/15/16	DJP	
Copper			0.223	mg/L	0.010	1.3	08/11/16 08:00	08/15/16	DJP	
6081218-21	Sample Location: Kitchen Break Room Sink									
Lead		1030	ND	mg/L	0.002	0.015	08/11/16 07:40	08/15/16	DJP	
Copper			0.086	mg/L	0.010	1.3	08/11/16 07:40	08/15/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6081218

### Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Tom Williams, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.  
This analytical report must be reproduced in its entirety.