

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 1031911

High Desert ESD
 2804 SW 6th Street
 Redmond, OR 97756
 REQ 1375

Project: General

 Client Contact: Bob Martin

Date Reported: 03/29/21
 Date Received: 03/19/21 12:10
 Sampled By: Bob Martin

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
1031911-01	Sample Location: Skyliner - Kitchen									
	Lead (¢)	1030	ND	ppb	1.0	15	03/18/21 08:32	03/22/21	DST	
1031911-02	Sample Location: Skyliner - S Bathroom									
	Lead (¢)	1030	ND	ppb	1.0	15	03/18/21 08:45	03/22/21	DST	
1031911-03	Sample Location: AHC - Kitchen									
	Lead (¢)	1030	ND	ppb	1.0	15	03/18/21 08:06	03/22/21	DST	
1031911-04	Sample Location: AHC - S.O. Classroom									
	Lead (¢)	1030	ND	ppb	1.0	15	03/18/21 08:03	03/22/21	DST	
1031911-05	Sample Location: HDREC - 2nd Flr Kitchen									
	Lead (¢)	1030	ND	ppb	1.0	15	03/18/21 05:12	03/22/21	DST	
1031911-06	Sample Location: HDREC - 1st Flr Kitchen									
	Lead (¢)	1030	ND	ppb	1.0	15	03/18/21 05:20	03/22/21	DST	
1031911-07	Sample Location: Manz - Kitchen									
	Lead (¢)	1030	ND	ppb	1.0	15	03/18/21 05:53	03/22/21	DST	
1031911-08	Sample Location: Manz - Classroom A									
	Lead (¢)	1030	ND	ppb	1.0	15	03/18/21 05:57	03/22/21	DST	
1031911-09	Sample Location: PEC - Hallway Sink									
	Lead (¢)	1030	2.9	ppb	1.0	15	03/18/21 04:42	03/22/21	DST	
1031911-10	Sample Location: PEC - Childrens Restroom									
	Lead (¢)	1030	1.3	ppb	1.0	15	03/18/21 04:40	03/22/21	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 1031911

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager