

April 27, 2018

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

SKYLINER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
7205063	MEETING	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	< 0.3	2018-04-27
7205053	MEETING	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	< 0.3	2018-04-27
7205054	MEETING	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	< 0.3	2018-04-27
7203658	NE	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	1.2 ± 0.2	2018-04-27
7205062	NE	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	< 0.3	2018-04-27
7205052	SE	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	< 0.3	2018-04-27
7205061	SW	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	0.5 ± 0.2	2018-04-27
7205060	UPPER E	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	< 0.3	2018-04-27
7205057	UPPER W	2018-04-23 @ 10:00 am	2018-04-26 @ 11:00 am	< 0.3	2018-04-27

Air Chek, Inc. 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498